


C7027A, C7035, C7044A Minipeeper Ultraviolet Flame Detectors

The C7027A, C7035A and C7044A detect the ultraviolet radiation emitted by combustion flames. The flame detectors are used with Honeywell flame safeguard controls to provide flame supervision for gas, oil, or combination gas-oil burners.



- C7027A, C7035A, and C7044A Flame Detectors are used with R7249A, R7290A, R7749B and R7849A,B Amplifiers and the appropriate Honeywell controls.

- C7044A may also be used with the following 50 Hz Honeywell combustion controls/amplifiers:
R4341/R7323
R4343/R7323
R4344/R7323

W C7027A has an integral collar threaded (internal 1/2-14 NPSM) for mounting on a one-half-inch sight pipe.

- C7035A has an integral collar threaded (internal 1-11-1/2 NPSM) for mounting on a one-inch sight Pipe.

- C7035A housing meets Underwriters Laboratories Inc. requirements for raintightness and complies with NEMA enclosure standards, types 4 and 4X.

- C7044A mounts with a two screw bracket. The UV sensor tube is enclosed in a stainless steel housing.

- C7044A has the capability of side or end viewing in flame monitoring applications.

- Because of their compact size, the C7027A and C7044A are particularly suitable for blast tube mounting.

- Properly installed, the C7027A and C7035A are pressure rated for 5 psi.

- C7035A ultraviolet radiation sensor tube is field replaceable.

- Two C7027A, C7035A, or C7044A Flame Detectors can be wired in parallel for difficult flame sighting installations.

CONTENTS

Specifications	2
Ordering Information	2
Installation	4
Adjustments and Checkout	7
Troubleshooting	10
Maintenance	10

Specifications

SUPER TRADELINE MODELS

SUPER TRADELINE models offer features not available on TRADELINE or standard models, and are designed to replace a widerange of Honeywell and competitive controls. SUPER TRADELINE models are selected and packaged to provide ease of stocking, ease of handling, and maximum replacement value. Specifications of SUPER TRADELINE models are the same as those of standard models except as noted below.

SUPER TRADELINE MODEL AVAILABLE:

C7027A10804 includes C1027A1023 Detector, 136733 Heat Block, and 390427B Bushing.

SUPER TRADELINE FEATURES:

- Heat block for insulating the detector from sight pipe temperatures above 215° F [102° C] up to 266° F [130° C].
- Bushing for mounting the detector on a 3/8 in. sight pipe.
- SUPER TRADELINE pack with cross reference label and Instructions, form 60-0638.

STANDARD MODELS

C7027A MINIPEEPER ULTRAVIOLET FLAME DETECTOR

AMBIENT OPERATING TEMPERATURE RATINGS:

0° F to 215° F [-18° C to 102° C], or -40° F to 215° F [-40° C to +102° C], depending on model.

MAXIMUM PRESSURE RATING: 5 psi [34.5 kPa].

MOUNTING: Collar with 1/2- 14 NPSM internal threads for mounting on a 1/2 in. sight pipe.

WIRING CONNECTIONS: Two 6 ft [1.83 m], color-coded, NBC Class 1 leadwires. (One model is available with 24 ft [7.32 m] leadwires.) Rear of detector has a clamp type connector for 1/2 in. flexible metallic conduit. (Models are available with 1/2 in. internally threaded spud connector instead of the clamp.)


DIMENSIONS: See Fig. 1.

REPLACEMENT PART: 129685 Flange Gasket.

NOTE: The ultraviolet radiation sensing tube is not field replaceable.

ACCESSORY: 136733 Heat Block, laminated plastic, for insulating the flame detector from sight pipe temperatures up to 266° F [130° C], 1/2-14 NPSM external threads on one end and 1/2-14 NPSM internal threads on the other end (see Fig. 5).

Fig. 1—Installation dimensions of C7027A, in in. [mm].



▲ MODEL AVAILABLE WITH 24 FOOT [7.32 METRE] LEADWIRES.

▲ MODELS AVAILABLE WITH SPUD CONNECTOR (1/2-14 NPSM INTERNAL THREADS) INSTEAD OF CLAMP TYPE CONNECTOR.

M1943

Ordering Information

When purchasing replacement and modernization products from your Flame Safeguard Authorized Distributor, refer to the TRADELINE® Catalog or price sheets for complete ordering number, and specify:

1. Order number.

2. Operating temperature range.

ORDER SEPARATELY:

1. Replacement parts, if desired.

2. Accessories, if desired.

If you have additional questions, need further information, or would like to comment on our products or services, please write or phone:

1. Your local Honeywell Residential and Building Controls Division Sales Office (check white pages of phone directory).

2. Residential and Building Controls Division Customer Satisfaction
 Honeywell Inc., 1885 Douglas Drive North
 Minneapolis, Minnesota 554224386 (612) 951-1000

In Canada-Honeywell Limited/Honeywell Liitee, 740 Ellesmere Road, Scarborough, Ontario M1P 2V9. International Sales and Service offices in all principal cities of the world. Manufacturing in Australia, Canada, Finland, France, Germany, Japan, Mexico, Netherlands, Spain, Taiwan, United Kingdom, U.S.A.

C7035A MINIPEEPER ULTRAVIOLET FLAME DETECTOR

FLAME DETECTION: End viewing.

AMBIENT OPERATING TEMPERATURE RATINGS: 0° F to 250° F [-18° C to 121° C], or -40° F to 250° F [-40° C to 121° C], depending on model.

MAXIMUM PRESSURE RATING: 5 psi [34.5 kPa].
MOUNTING Collar with 1- 1 1/2 NPSM internal threads for mounting on a 1 in. sight pipe. (The DIN approved C7035A1064 has 1-11 BSP.P1 threads.)

WIRING CONNECTIONS: Two 6 ft. [1.83 m], color-coded NBC Class 1 leadwires rated for 600° F [204° C]. One model is available with 12 ft. [3.66 m] leadwires. Rear of detector has 1/2- 14 NPSM internal threads for connecting to a conduit. The DIN approved C7035A1064 has 1/2-14 BSP-F threads.

DIMENSIONS: See Fig. 2.

REPLACEMENT PARTS:

- 129808 Flange Gasket.
- 129464M Ultraviolet Sensing Tube, 0° F to 250° F [-18° C to 121° C].
- 129464N Ultraviolet Sensing Tube, -40° F to 250° F [-40° c to 121° C].

C7027A AND C7035A

APPROVALS:

- Underwriters Laboratories Inc. listed: File No. MP268.
- Canadian Standards Association certified: Master Report LR 95329-1.
- Factory Mutual approved.
- Industrial Risk Insurers acceptable.
- DIN approved models: C7027A1056, C7035A1049, C7035A1064.

ACCESSORIES:

- 118367A Swivel Mount; provides adjustable positioning of the C7027A or C7035A.

C7044A MINIPEEPER ULTRAVIOLET FLAME DETECTOR

DETECTION: Housing has two openings to permit either sideorendviewing. Sideviewing is 1/8 as sensitive as end viewing.


AMBIENT OPERATING TEMPERATURE RATINGS: 0° F to 215° F [-18° C to 102° C].

MOUNTING: Bracket (included in 4074 BVK Bag Assembly), secured by two 8-32 RHIS (European M-4) screws (not included).

WIRING CONNECTIONS: Two 6 ft. [1.83 m], color-coded, NBC Class 1 leadwires. Rear of detector has a clamp type connector for 1/2 in. flexible metallic conduit.


DIMENSIONS: See Fig. 3.

Fig. 2—Installation dimensions of C7035A, in in. [mm].



- 1 DIN APPROVED C7035A1064 HAS 1-11 BSP.P1 INTERNAL THREADS.
- 2 DIN APPROVED C7035A1064 HAS 1/2-14 BSP-F INTERNAL THREADS.
- 3 MODEL AVAILABLE WITH 12 FOOT [3.66 METRE] LEADWIRES. M1945

Fig. 3—Installation dimensions of C7044A, in in. [mm].



Installation

CAUTION

Ultraviolet radiation sensing tubes have a life expectancy of 40,000 hours of continuous use within the flame detector's specified ambient temperature and voltage ratings. **Wearout** of an ultraviolet radiation sensing tube results in failure of the UV sensor to properly discriminate between flame conditions.

The C7027A, C7035A and C7044A Flame Detectors should only be used on burners that cycle on/off periodically or, in the absence of cycling, are periodically checked for proper operation.

Recommended industry standards for the frequency of sensor checks, either through cycling (employing safe-start check methods) or periodic maintenance, vary between once every ten seconds and once every week, depending on the standard used and the application needs.

Consult the equipment manufacturer or the governing standard for recommendations about frequency of checks.

Controls incorporating safe-start checks, and sensors and controls employing constant check means are available from Honeywell. See your Honeywell representative for specific information.

WHEN INSTALLING THIS PRODUCT..

1. Read these instructions carefully. Failure to follow them could damage the product or cause a hazardous condition.
2. Check the ratings given in the instructions and on the product to make sure the product is suitable for your application.
3. Installer must be a trained, experienced, flame safeguard control technician.
4. After installation is complete, check out product operation as provided in these instructions.

CAUTION

1. The C7027A, C7035A and C7044A Flame Detectors must be used with Honeywell flame safeguard controls (primaries, programmers, multiburner systems, and burner management systems). Using with controls not manufactured by Honeywell could result in unsafe conditions.
2. Disconnect power supply before beginning installation to prevent electrical shock or equipment damage; more than one disconnect may be involved.
3. Read the installation instructions before starting the installation.
4. All wiring must be NEC Class 1 (line voltage).
5. The flame detector must be positioned so that it sights the flame and does not respond to the UV radiation emitted by sparks generated by a spark igniter. The Q624A Solid-State Igniter may be useful in difficult installations.

BASIC REQUIREMENTS FOR ULTRAVIOLET DETECTOR INSTALLATIONS

All flames emit ultraviolet radiation, invisible to the human eye but detected by the UV sensing tube. There are two important factors in UV detector installation:

1. The detector must have a line-of-sight view of the flame.
2. The detector must not be exposed to other sources of ultraviolet radiation, the most common being ignition spark. Other sources are listed in the next section.

Because it is necessary for the detector to actually see the flame, it is desirable to locate the detector as close to the flame as physical arrangement and temperature restrictions permit.

Sighting requirements for different types of flame supervision are:

1. Pilot flame only---Sighting must be along the axis of the pilot flame. The smallest pilot flame that can be sighted must be capable of igniting the main burner (see Pilot Turndown Test, page 9).
2. Main flame only---Sighting must be at the most stable part of the flame for all firing rates.
3. Pilot and main flame---Sighting must be at the junction of both flames.

OTHER RADIATION SOURCES SENSED BY THE UV DETECTOR

Examples of radiation sources (other than flame) that could actuate the detection system are:

Ultraviolet Sources:

Hot refractory above 2800° F [1371° C].

Spark:

- . ignition transformers.
- . welding arcs.
- . lightning.

Gas lasers.

sun lamps.

Germicidal lamps.

Gamma Ray and X-ray Sources:

Diffraction analyzers.

Electron microscopes.

Radiographic X-ray machines.

High voltage vacuum switches.

High voltage condensers.

Radioscopes.

Except under unusual circumstances, none of these sources except hot refractory and ignition spark would be present in or near the combustion chamber.

The detector may respond to hot refractory above 2800° F [1371° C] if the refractory surface represents a significant percentage of the field of view of the detector. If the temperature of the hot refractory causes the flame relay (in the flame safeguard control) to pull in, reposition the sight pipe so the detector views a cooler area of the refractory.

Ignition spark is a source of ultraviolet radiation. **When installing the C70217A, C7035A, or C7044A Flame Detector, make sure it does not respond to ignition spark (see Ultraviolet Response Test, page 9).** If the installation is such that response to the ignition sparks cannot be avoided, the Q624A Solid-State Ignition Transformer may eliminate the ignition spark response. The Q624A, when properly installed, prevents C7027A, C7035A, and C7044A ignition spark response by alternately activating the spark generator and the **W sensing tube.**

MOUNTING A C7027A OR C7035A LOCATE THE SIGHT PIPE

The location of the sight pipe is the most critical part of the installation. A black iron pipe is recommended. Do **not** use a stainless steel or galvanized pipe because its internal surface blackens with use as deposits from the combustion chamber settle on it. Initially, its shiny internal surface reflects ultraviolet radiation, which could result in a satisfactory flame signal, even though the pipe may be improperly located. As it blackens, less ultraviolet radiation is reflected **and** the flame signal may become marginal.

Under optimum sighting conditions, the C7027A and C7035A Flame Detectors can detect most common gas and oil combustion flames at a distance of six feet. The critical factors in determining the flame-detector distance separation are the optimized flame signal (current or voltage) and the flame detector temperature. Other factors may be influential and are associated with the specific installation. For minimum flame signals, see Table 1 and for ambient operating temperatures, refer to Specifications, page 2.

Use 1/2 in. pipe for a C7027 and 1 in. pipe for a C7035. Since no two situations are likely to be the same, length and sighting angle of the pipe must be determined at the time and place of installation. **Generally, it is desirable to have the sight pipe tilting downward to prevent soot or dirt buildup.**

If a C7027A is to be used for a blast tube installation, its location should be determined by the burner manufacturer; contact the manufacturer before making any modifications to the installation.

In locations where water is usually sprayed on the body of the detector, use a C7035A. Internal threads in its base permit the use of waterproof flexible conduit for this type of application.

PREPARE HOLE IN WALL OF COMBUSTION CHAMBER


Cut a hole of the proper diameter for the sight pipe in the **wall of the combustion chamber at the selected location.** Flare the hole to leave room for small adjustments of the sighting angle. The taper of the hole should be about 1 in. for every 3 in. [25 mm for every 76 mm] of wall thickness.

MOUNTING THE SIGHT PIPE (FIG. 4)

Thread one end of the pipe to fit the mounting collar on the detector. Cut the pipe to the desired length (as short as practicable), and at an angle so it fits flush with the wall of the combustion chamber. Tack weld the pipe to the wall in a trial position. **Do not permanently weld the sight pipe in place until after completing the Adjustments and Checkout beginning on page 7.**

NOTE: If you use a swivel mount (part no. 118367A) and you are positive about the location and sighting angle, you can permanently weld the pipe.

Fig. 4—Mounting sight pipe.



SIGHT PIPE VENTILATION

It may be necessary to ventilate the sight pipe to cool the flame detector or to clear the sight pipe of UV radiation absorbing substances such as smoke, excessive moisture or, in some instances, unburned fuel.

For a negative pressure combustion chamber, drilling a few holes in the section of the sight pipe outside of the combustion chamber will allow air at atmospheric pressure to flow through the sight pipe into the chamber. A perforated pipe nipple between the sight pipe and the detector can also be used (see Fig. 5).

Fig. 5—Mounting a C7027A on a combustion chamber (viewed from above). C7035A mounting is similar.





Fig. 6—Mounting dimensions of 136733 heat block, in in. [mm].



For a positive pressure combustion chamber, connect a supply of pressurized air from the burner blower through the sight pipe into the chamber. The supply air pressure must be greater than the chamber pressure.

SWIVEL MOUNT

To facilitate proper sighting of the flame, a swivel mount (part no. 118367A) is available. The swivel mount will require a 3/4 to 1/2 in. reducer and a 1/2 in. close nipple to mount a C7027A, or a 1 in. pipe at least 2-1/2 in. [163.5 mm] long to mount a C7035A. For mounting details, refer to form 60-0361 for the 118367A Swivel Mount.

USING A HEAT BLOCK WITH A C7027 (Fig. 6)

If the temperature of the sight pipe will become high enough to cause the C7027A to overheat (above 215° F [102° C] up to 266° F [130° C], screw a 136733 Heat Block (order separately) onto the sight pipe before mounting the detector.

MOUNT THE DETECTOR (Fig. 5)

Mount the detector onto the sight pipe, pipe tee, nipple, or other fitting. Make sure the flange gasket is in place inside the mounting collar on the detector, and then screw the collar onto the sight pipe or fitting.

NOTE: If a window is installed between the UV detector and the flame, it must be fabricated from quartz or fused silica. Ordinary glass filters out ultraviolet radiation.


MOUNTING A C7044A ON A BLAST TUBE (Fig. 7)

The C7044 is designed to be mounted on the blast tube of a burner. The exact location should be determined by the burner manufacturer. Contact the manufacturer before making any modifications to the installation.

! CAUTION

The C7044 will allow air leakage through its housing. It should not be located in a atmosphere of fuel vapors under positive pressure. The C7027 or C7035 should be used if internal pressure sealoff is required.

Fig. 7—Mounting C7044A on blast tube.



The C7044 is mounted in a 29/32 in. [23.0 mm] hole in the blast tube. The mounting bracket is fastened to the blast tube with 2 screws on 1-27/64 in. [36.1 mm] centers.

The mounting bracket is designed so that the detector can be removed from the blast tube for cleaning and then replaced without disturbing the sighting angle. Loosen the 2 screws holding the bracket to the blast tube, but do not loosen the clamp screw on the bracket. Twist both the bracket and detector to remove them.

WIRING (All Models-Fig. 8)

Caution

The blue (tan with blue tracer with C7035A1080) leadwire must be connected to the F terminal of the flame safeguard control subbase or terminal strip and the white (tan leadwire without blue tracer with C7035A1080) to the G terminal (see Fig. 8). Failure to observe the circuit polarity by reversing the leadwires (even momentarily) may cause the flame detector to improperly supervise the combustion flame.

1. Disconnect power supply before beginning installation to prevent electrical shock and equipment damage. All wiring must comply with applicable electrical codes, ordinances, and regulations. Use NEC Class 1 wiring.

2. If the leadwires are not long enough to reach the terminal strip or wiring subbase, make the required splices in a junction box.

3. If splicing is necessary, use moisture-resistant wire suitable for at least 167°F [75°C] if the detector is used with a flame safeguard primary control, or at least 194°F [90°C] if used with a flame safeguard programming control.

4. For high temperature installations, use Honeywell Specification no. R1298020 or equivalent for the F leadwire. (This wire is rated up to 400°F [204°C] for continuous duty. It is tested for operation up to 600V and breakdown up to 7500V.) For the other leadwires, use moisture-resistant wire selected for a temperature rating above the maximum operating temperature.

IMPORTANT: Do not run the flame detector wiring in the same conduit with high voltage ignition transformer wires.

CONNECTING DETECTORS IN PARALLEL


For a flame that is difficult to sight, using two flame detectors connected in parallel will reduce the occurrence of nuisance shutdowns. If only one of the parallel detectors loses the flame signal, the other will continue to indicate the presence of the flame and keep the burner in operation.

When the flame detectors are connected in parallel, the low level background signals are additive. Therefore, no more than two C7027A, C7035A, or C7044A Flame Detectors should be paralleled. Furthermore, the background signal increases as temperature decreases. Because of this, the minimum ambient operating temperature must be increased when the C7027A, C7035A or C7044A Flame Detectors are paralleled.

When using detectors rated for a minimum of 0° F [-18° C], limit the minimum ambient temperature at the detectors to 32° F [0° C]. When using detectors rated for a minimum of -40° F [-40° C], limit the minimum ambient temperature at the detectors to -10° F [-23° C].

Connect the blue leadwires of both detectors to the F terminal of the wiring subbase or terminal strip, and the white leadwires of both detectors to the G terminal, as shown in Fig. 8.

Fig. 8—Wiring C7027A, C7035A, and C7044A flame detectors in parallel.



EARTHGROUND

The detector and the flame safeguard control must be connected to earth ground. A convenient method of accomplishing this is to connect the detector to the flame safeguard control with a flexible conduit, or ensure a good ground connection at the mounting bracket.

Adjustments and Checkout

Before welding the C7027A or C7035A sight pipe in its final location, or before tightening the C7044A clamp screw, complete both the adjustments and checkout tests that follow and any required by the burner manufacturer.

UV SENSOR TUBE TEST

NOTE: For initial burner lightoff, consult the burner manufacturer instructions or the instructions for the flame safeguard control.

During the initial burner lightoff, make sure the flame safeguard control starts (i.e., the load relay, usually 1K, pulls in). If it does not start, visually check the sensing tube in the C7027A, C7035A, or C7044A flame detector. If the tube continues to glow when no flame is present, replace the sensing tube (C7035A), or replace the detector (C7027A or C7044A).

ADJUST DETECTOR SIGHTING POSITION

With the flame detector installed and burners running, adjust the position of the flame detector for optimum flame signal. The flame signal will be read in microamps or voltage (Vdc) depending on the Honeywell flame safeguard combustion control used.


Most existing Honeywell flame safeguard controls incorporate a flame current jack on the flame amplifier or on the control itself. The flame signal can be measured with a volt-ohmmeter such as the Honeywell W136A. To measure the flame current (signal), use a cable connector (part number 196146, included with the W136A) in conjunction with the meter. With the W136A (or equivalent) positioned at the zero to 25 microampere scale, make connections from the meter probes to the two ends of the cable connector plug (red to red, black to black). Make these connections before inserting the plug end of the connector plug into the flame jack of the control or control amplifier (see Fig. 9a). Read the flame signal in microamperes directly from the W136A meter. Refer to Table 1 for the minimum acceptable flame currents.

The R7749B and R7849A,B Amplifiers used with the Honeywell BCS 7700 and 7800 SERIES controls, respectively, have a dc voltage flame signal output.



For the R7749B Amplifier, a volt-ohmmeter with a zero to 5 or 10 Vdc scale and a minimum sensitivity of 20,000 volts/ohm is suggested.

For the R7849A,B Amplifiers used with the 7800 SERIES controls, a volt-ohmmeter with a zero to 5 or 10 Vdc scale and a minimum sensitivity of one megohm/volt is recommended, (see Fig. 9c).

Measure the flame signal voltage as illustrated in Figs. 9b and 9c. Be careful to connect the positive meter lead to the positive (+) amplifier jack and the negative meter lead to the negative (-) amplifier jack (BCS 7700) or the (-) jack for a 7800 SERIES control. If the BCS 7700 and SERIES 7800

Fig. 9a—Measuring microamp flame signal.

controls have the optional Keyboard Display Module, a zero to five Vdc reading will be displayed on the module.

Fig. 9b—Measuring the BCS 7700 flame signal voltage.**Fig. 9c—Measuring flame signal voltage of 7900 SERIES controls.**

Move the flame detector and sight pipe (if not permanently attached to the burner/boiler) to view the flame from various positions. Allow a few seconds for the meter reading to stabilize. A maximum steady microamp or voltage reading is desirable. The flame signal must be above the minimum acceptable level for the flame safeguard control and associated amplifier as indicated in Table 1.

Measure the flame signal for the pilot alone, the main burner flame alone, and both together (unless monitoring pilot only when using an intermittent pilot or supervising the main flame only when using direct spark ignition). Also, measure the flame signal at low and high firing rates and while modulating (if applicable).

With the **flame** detector in its final position, all flame signals must be steady with a current/voltage value as **indicated** in Table 1. If the minimum signal cannot be obtained or is **unstable**, refer to **Troubleshooting**, page 10.

PILOT TURNDOWN TEST

If the detector is used to prove a pilot flame before the main fuel valve can be opened, perform a Pilot Turndown Test. Follow the **procedures** in both the Instructions for the appropriate flame safeguard control, and in the burner manufacturer's instructions.

TABLE 1—IFLAME SIGNAL.

Flame Detector	Plug-in Amplifier	Honeywell Flame Safeguard Control	Minimum Acceptable Steady Current (microamps)	Maximum Current Expected (microamps)	Minimum Acceptable Voltage (Vdc)	Maximum Voltage (Vdc)
	R7249A	BC7000 + PM720	3.5	7.5		
	R7749B (AMPLI-CHECK™)	BCS7700A			2.2	4.98
	R7249A	R4075C,D,E	3.5	7.5		
		R4138C,D	3.5	7.5		
		R4140G,L,M	3.5	7.5		
	R7290A	R4795A,D	1.5	2.25		
	None	R7023C,	1.5	2.25		
		R7795A,C,E,G	1.5	2.25		
	R7849A or R7849B (AMPLI-CHECK™)	RM7800E,G,L,M			1.25	5.0
		RM7823A			1.25	5.0
		RM7838A,B			1.25	5.0
		RM7840E,G,L,M			1.25	5.0
		RM7885A			1.25	5.0
		RM7890A,B			1.25	5.0
		RM7895A,B,C,D			1.25	5.0
	None	RA890G	1.5	2.25		

ULTRAVIOLET RESPONSE TESTS IGNITION SPARK RESPONSE TEST

Test to be **sure** that ignition spark is not actuating the **flame** relay (usually 2K) in the flame safeguard control.

1. Close the pilot and main burner manual fuel shutoff valves.

2. Connect the appropriate meter to the flame safeguard control amplifier. Start the burner and run through the ignition period. Ignition spark should occur, but the flame relay must not pull in. The flame signal should not be more than 0.25 microamp.

3. If the flame relay does pull in, reposition the flame detector to increase the distance between the flame detector and the ignition spark. If the flame detector is not in the line of sight of the ignition spark but appears to respond to the spark, it may be responding to reflected spark generated UV radiation. If so, relocate the flame detector so it does not receive the reflected UV radiation. It may be necessary to construct a barrier to block the UV radiation generated by the spark from the flame detector view.

4. Continue making the adjustments until the flame signal due to ignition spark is less than 0.25 microamp or 1.25 Vdc.

5. The use of the Q624A solid-state ignition transformer may also provide a method to eliminate the C7027A, C7035A, or C7044A flame detector response to UV radiation generated by ignition spark. The Q624A prevents flame detector response to ignition spark by providing alternating periods of spark generation and UV sensor activation.

RESPONSE TO OTHER ULTRAVIOLET SOURCES

Some sources of artificial light produce small amounts of ultraviolet radiation. Under certain conditions, an ultraviolet detector will respond to them as if it is sensing a **flame**. *Do not use an artificial light source to check the response of an ultraviolet detector.* To check for **proper** flame detector operation, test for flame failure response under all operating conditions.

WELD THE SIGHT PIPE (or Tighten the C7044A Clamp Screw)

When the flame signal is **acceptable** after all adjustments are made, remove the flame detector and weld the sight pipe in its final position. If you are using a swivel mount, the pipe may already be welded. Then reinstall the flame detector.

NOTE: If using a C7044A Detector with no sight pipe, do not remove the detector; tighten the clamp screw securely.

FINAL CHECKOUT

Before putting the burner into service, check out the installation using the procedures in the Checkout section of the Instructions for the appropriate flame safeguard control. After completing the checkout, run the burner through at least one complete cycle to verify correct operation.

Troubleshooting

CAUTION

1. Be extremely careful while troubleshooting the detector; line voltage is present on some of the terminals when power is on.
2. Open the master switch to disconnect power before removing or installing the detector.

INADEQUATE FLAME SIGNAL

If a satisfactory flame signal cannot be obtained while adjusting the sighting position of the detector, perform the procedures indicated in steps 1 through 7. If other difficulties are encountered in the system, **refer to Troubleshooting in the Instructions for the appropriate Honeywell flame safeguard control.**

1. Check for proper line voltage. Make sure the master switch is closed, connections are correct, and power supply is the correct voltage and frequency.
2. Check the detector wiring for defects, including:
 - incorrect connections.
 - wiring type or size of wire.
 - deteriorated wire.
 - open circuits.
 - short circuits.
 - leakage paths caused by moisture, soot, or dirt.

3. With the burner running, check the temperature at the detector. When it exceeds 215° F [102° C] for a C7027 or C7044, or 250° F [121° C] for a C7035:

- use a heat block (part no. 136733) if using a C7027A Flame Detector.
 - add the additional insulation between the wall of the combustion chamber and the detector.
 - add a shield or screen to reflect radiated heat away from the detector, or
 - add cooling (refer to Sight Pipe Ventilation, page 5).
4. Remove the detector and clean the viewing window with a soft, clean cloth.
 5. Clean the inside of the sight pipe (if one is used) before reinstalling the detector.
 6. If the flame signal continues to be too low, replace the plug-in amplifier (if the control has one).
 7. If you still cannot obtain a proper flame signal, replace flame detector (C7027A, C7044A) or UV radiation sensing tube (C7035A).

IMPORTANT: At the completion of troubleshooting, be sure to perform the Adjustments and Checkout beginning on page 7.

Maintenance

PERIODIC MAINTENANCE

1. Clean the viewing window and sight pipe (if used) when necessary. Remove the detector and use a soft, clean cloth to remove accumulated contaminants from the UV radiation sensor tube glass envelope.
3. Ultraviolet sensing tubes have a life expectancy of 40,000 hours of continuous use within the ambient temperature and voltage ratings. Replace the sensing tube in the C7035, or replace the C7027 or C7044 Detector, at appropriate intervals.
3. Keep the flame detection system adjusted for the smoothest, most reliable operation as recommended by the burner manufacturer.

CLEANING THE C7044A DETECTOR

- When necessary, clean the C7044 Flame Detector by using the following procedure:
1. Loosen the two screws holding the C7044 mounting bracket to the blast tube. To remove, twist the bracket and detector. **Do not** loosen the clamp screw that holds the mounting bracket to the detector.
 2. Clean the viewing window with a soft, clean cloth.
 3. Insert the detector into the mounting hole, and to realign it, twist against the mounting screws.
 4. Tighten the two mounting screws.